1333 NW Eastman Parkway, Gresham, OR 97030 – Phone: 503-618-2248

SHORT-TERM RENTAL (STR) REGISTRATION  VACATION HOME RENTAL INSPECTION CHECKLIST				
PROPERTY:	REGISTRATION NUMBER:			
INSPECTION:	INSPECTION DATE:			
INSPECTOR:	(Owner/Agent on site during inspection?)			
Inspection passed? Yes. You will receive your Registration Certificate via email.  No. A re-inspection fee of \$125 is required. Visit GreshamOregon.gov/STR for information.				
GENERAL SAFETY				
Requirement	<u>Comments</u>			
House number is visible from the street.				
At least one fire extinguisher on every floor of the home in conspicuous, easy-to-grab spots, near exits that are accessible within seconds. Place one near the kitchen exit away from a stove or oven.				
Doors are easily accessible with working locks and not broken. All bedrooms shall have the capability to be locked.				
Windows are easily accessible with working locks and not broken.				
Hot water heater is set no higher than 120 degrees Fahrenheit.				
Stairs have at least one handrail.				
Things that can burn are at least 3 feet from the furnace, fireplace (should have screen and hearth), heater, appliances, and stovetop. Any flammables are stored properly.				
A safe, continuous, and unobstructed path to public way.				
There is no significant presence of mold, dampness or water damage.				
Appliances are all in a safe, working condition.				
Habitable rooms have proper heat source. (Installed force air unit, electric heaters, etc. capable of maintaining 68°F at				

SMOKE & CARBON MONOXIDE DETECTORS					
Requirement	Smoke Detectors	Carbon Monoxide  Detectors		<u>Comments</u>	
All operational					
		On every level Outside every sleeping area		O square feet), there is an average of at least 1 smoke alarm	
for every 500 feet.					
BEDROOMS Requirement		Comments			
Bedroom is a legal sleeping room per definition: Minimum of 70 square ft. with minimum horizontal distance of wall of 7 feet. Must have at least one lockable door and one window directly opening to outside of dwelling (minimum NET opening area of 5.7 square feet). Must also have a proper heat source (Installed force air unit, electric heaters, etc. capable of maintaining 68°F at a height of 3'0" above floor. No portable heaters allowed.)  All bedrooms have exit door and exit window in good working condition (not blocked by furniture, damaged or barred and are easily openable) and all second-floor bedrooms have an emergency escape ladder stored in a conspicuous place.					
Requirement				<u>Comments</u>	
All electrical appears to be in safe and working condition (no exposed or damaged wiring, electrical panel properly covered and accessible, faceplate covers in place, extension cords are not used as fixed wiring).					
POSTINGS / REQUIREMENTS					
Requirement				<u>Comments</u>	
Good Neigh	nbor Guidelines posted in STR o	r provided in			
Parking ava	ilable as required.				

## The Short-Term Residential Code's Bedroom Requirement At least two exits At least one window (incl. windows & doors) (min. clear opening of 5.7 SF) Ceiling at proper building code height (7'0" min) Door w/ capability Minimum Room Area: of being locked At least 70 SF Installed heating in size source (min. horizontal wall distance of 7') \*Closet preffered but not mandatory